

**DNIT for "Electrical wiring in House No. 49 Type 1 in MDU, Rohtak. (E.I)**

Sr. No. HSR		Description	Qty.	Unit	Rate to be quoted by Agency
1	23.5.1.1	Wiring only in 1.5 sqmm PVC insulated copper conductor cable for LIGHT/FAN/Call bell point in existing conduit pipe and MS boxes including cost of Bakelite cover for MS box, switch, wall socket, ceiling rose/connector etc.	24	Nos.	
2	23.5.4.1	Wiring in existing conduit and MS box for 3-pin 5amp. Plug point by using 2 no 1.5 sqmm FRLS copper wire and 1 no 1.5 Sqmm FRLS copper wire , including providing 1 no 5/6 Amp 3/5 pin socket and 1 no 5/6 Amp switch etc complete as required	8	Nos.	
3	23.5.5.1	Wiring in existing conduit system for 3-pin 15amp. Plug point by using 2 no 4 sqmm FRLS copper wire and 1 no 4 Sqmm FRLS copper wire for earthling, including providing 1 no 15/16 Amp 3/6 pin socket and 1 no 15/16 Amp switch etc complete as required	6	Nos.	
4	23.5.6.1	Wiring main and sub mains in two single core for phase and neutral wire and one single core for earth wire PVC insulated Copper conductor cable 1100 Volts grade in existing MS/PVC Conduit etc as required. 1run of Size 1.50 Sqmm(1/1.40mm	77	mtr	
5	23.5.6.2	Wiring main and sub mains in two single core for phase and neutral wire and one single core for earth wire PVC insulated Copper conductor cable 1100 Volts grade in existing MS/PVC Conduit etc as required. 1 run of Size 2.50 Sqmm(1.1.80mm)	59	mtr	
6	23.22.4.3	Supply and erection of double door sheet steel enclosure distribution board suitable for MCBS and ELCBS etc. recessed in wall including bonding to earth with all labour and material required to complete the job in all respect up to the entire satisfaction of the Engineer-in-Charge of the work. SPN DB Double Door 12 way ( 2 incoming and 10 outgoing)	1	Each	
7	23.22.5.1	Supply and erection of miniature circuit Breaker 240/415 V in the existing distribution board including making necessary connections 6 amp. to 32 amp Single Pole	10	Each	
8	23.22.5.4	Supply and erection of miniature circuit Breaker 240/415 V in the existing distribution board including making necessary connections 40 amp to 63 amp. Double pole	1	Each	

**MAHARSHI DAYANAND UNIVERSITY, ROHTAK**  
**NOTICE INVITING QUOTATIONS**

Percentage/item rate quotations are hereby invited by the undersigned for and on behalf of Registrar, M.D. University, Rohtak for the below noted work from the suppliers/Agencies/Contractors/societies registered with Haryana P.W.D. B & R, M.E.S. & Central P.W.D. UHBVN/DHBVN or any other State/Central Govt. Department for electrical works on dated 24/6/2025 at 3 PM. Quotations will be opened at the same date and time in the presence of quotationers or representative who may like to be present at that time. However, preference will be given to societies first. If two or more societies participated and found eligible. DNIQ may be seen on University website or in the office of Sub-Division.

Description	App.Amt.	Earnest Money	Time Limit
"Electrical wiring in House No-47 Type-I, in M.O.U, Rohtak",		29200/-	15 Days

**Conditions:-**

1. The work will be carried out strictly in accordance with the PWD Haryana specification and approved DNIQ.
2. Other taxes will be deducted as applicable time to time.

Sub-Divisional Engineer (Elect.)

o/c M.D. University, Rohtak

S.O. (Elect.) 2025/ 889-91 Dated 17/6/25

Cope of the above is forwarded to the following for information and necessary action:-

1. Executive Engineer C-II, M.D. University, Rohtak

Notice Board

Contractors/Agencies

Sub-Divisional Engineer (Elect.)

o/c M.D. University, Rohtak